

Message

From: Green, Margaret [/O=EXCHANGELABS/OU=EXCHANGE ADMINISTRATIVE GROUP (FYDIBOHF23SPDLT)/CN=RECIPIENTS/CN=BF88FE211E344A94B322C29A7755D44C-MGREEN10]
Sent: 10/3/2019 12:37:23 PM
To: French, Linda [Linda.French@mottmac.com]
Subject: RE: New Kensington- Joe Ditty Retirement

Hi Linda,

My apologies Linda, I thought I sent this last week but it got saved to my drafts. What we commonly recommend is that you can average them together for a monthly average but they would be assessed separately in regards to compliance with a daily maximum limit. You could look at it the same way if just the industrial user took multiple samples on the same day. At the end of the day, even though the samples were taken on the same day, they are different samples (not split) and therefore they would get averaged.

I hope this helps. As always, let me know if you need anything else.

Best,

Maggie

From: French, Linda <Linda.French@mottmac.com>
Sent: Tuesday, September 24, 2019 9:08 AM
To: Green, Margaret <green.margaret@epa.gov>
Subject: RE: New Kensington- Joe Ditty Retirement

Hi Maggie,

Thank you for alerting me to this signatory requirement.

I also had a question please. I can't seem to find an answer from the guidance documents so I would appreciate your input. The question is if an industrial user conducts a sampling event on the same day as the Authority, do the results get averaged to arrive at a single result for each parameter or are each sample's results evaluated separately for the purpose of assessing compliance with the daily limit? I understand if a single sample is split between the Authority and the industrial user the results get averaged, but if there two separate samples does averaging still apply?

Thanks for your help.

Linda French

Project Scientist

D +1 412 497-2912
linda.french@mottmac.com

From: Green, Margaret <green.margaret@epa.gov>
Sent: Monday, September 16, 2019 12:09 PM
To: French, Linda <Linda.French@mottmac.com>
Subject: New Kensington- Joe Ditty Retirement

Hi Linda,

In response to your letter dated July 16, 2019 regarding Joe Ditty's retirement in December 2019 there is one thing that comes to mind that I must note. If you are going to be signing the annual report pretreatment performance summary page I will need a signatory certification allowing you to sign on behalf of the Authority. I am attaching the signatory certification sample language to this email. Nothing else comes to mind at the moment but if it does I will be in touch.

Thank you for letting us know.

Best,

Maggie

Margaret Green
Environmental Engineer
Clean Water Branch | Water Division
U.S. EPA Region 3 (3WD41)
1650 Arch St., Philadelphia, PA, 19103
green.margaret@epa.gov | (215) 814-5736